



Product Service

Attestation of Conformity

No. N8A 109212 0003 Rev. 00

Holder of Certificate: **Ningbo Lefeng New Energy Co., Ltd**
No. 55 Haihe Road,
Binhai Industrial Park, Xiangshan County,
315700 Ningbo
PEOPLE'S REPUBLIC OF CHINA

Product: **Crystalline Silicon Terrestrial Photovoltaic (PV) Modules**
Mono-Crystalline Silicon Photovoltaic Module

This Attestation of Conformity is issued on a voluntary basis according to the Low Voltage Directive 2014/35/EU relating to electrical equipment designed for use within certain voltage limits. It confirms that the listed equipment complies with the principal protection requirements of the directive and is based on the technical specifications applicable at the time of issuance. It refers only to the particular sample submitted for testing and certification. For details see: www.tuvsud.com/ps-cert

Test report no.: 704062104603-00

Date, 2022-01-13

(Zhulin Zhang)

Page 1 of 2

After preparation of the necessary technical documentation as well as the EU declaration of conformity the required CE marking can be affixed on the product. The declaration of conformity is issued under the sole responsibility of the manufacturer. Other relevant EU-directives have to be observed.



Product Service

Attestation of Conformity

No. N8A 109212 0003 Rev. 00

Model(s):

LFxxxM12-66H, xxx=620 to 670 in step of 5,
 LFxxxM12-60H, xxx=565 to 610 in step of 5,
 LFxxxM12-55H, xxx=520 to 555 in step of 5,
 LFxxxM12-54H, xxx=510 to 545 in step of 5,
 LFxxxM12-50H, xxx=470 to 505 in step of 5,
 LFxxxM10-72H, xxx=520 to 555 in step of 5,
 LFxxxM10-66H, xxx=480 to 505 in step of 5,
 LFxxxM10-60H, xxx=435 to 460 in step of 5,
 LFxxxM10-54H, xxx=390 to 415 in step of 5,
 LFxxxM8-72H, xxx=420 to 465 in step of 5,
 LFxxxM8-66H, xxx=390 to 425 in step of 5,
 LFxxxM8-60H, xxx=355 to 385 in step of 5,
 LFxxxM6-72H, xxx=380 to 415 in step of 5,
 LFxxxM6-60H, xxx=320 to 345 in step of 5,
 xxx is standing for rated output power at STC

Parameters:

Construction:	Framed, with Junction box, Cable and Connectors.
Safety Class:	Class II
Maximum System Voltage:	1500 V DC
Fire Safety Class:	Class C according to UL790
Test Laboratory:	Yangzhou Opto-Electrical Products Testing Institute; No. 10 West Kaifa Road, Yangzhou, 225009 Jiangsu, P. R. China

Tested according to:

EN IEC 61730-1:2018
 EN IEC 61730-1:2018/AC:2018-06
 EN IEC 61730-2:2018
 EN IEC 61730-2:2018/AC:2018-06

Page 2 of 2

After preparation of the necessary technical documentation as well as the EU declaration of conformity the required CE marking can be affixed on the product. The declaration of conformity is issued under the sole responsibility of the manufacturer. Other relevant EU-directives have to be observed.