



Product Service

CERTIFICATE

No. Z2 109212 0002 Rev. 00

Holder of Certificate: Ningbo Lefeng New Energy Co., Ltd

No. 55 Haihe Road,
Binhai Industrial Park, Xiangshan County,
315700 Ningbo
PEOPLE'S REPUBLIC OF CHINA

Certification Mark:



Product:

**Crystalline Silicon Terrestrial Photovoltaic (PV) Modules
Mono-Crystalline Silicon Photovoltaic Module**

The product was tested on a voluntary basis and complies with the essential requirements. The certification mark shown above can be affixed on the product. It is not permitted to alter the certification mark in any way. In addition, the certification holder must not transfer the certificate to third parties. This certificate is valid until the listed date, unless it is cancelled earlier. All applicable requirements of the testing and certification regulations of TÜV SÜD Group have to be complied. For details see: www.tuvsud.com/ps-cert

Test report no.: 704062104603-00

Valid until: 2026-12-20

Date, 2022-01-13

(Zhulin Zhang)



Product Service

CERTIFICATE

No. Z2 109212 0002 Rev. 00

Model(s):

LFxxxM12-66H, xxx=620 to 670 in step of 5,
LFxxxM12-60H, xxx=565 to 610 in step of 5,
LFxxxM12-55H, xxx=520 to 555 in step of 5,
LFxxxM12-54H, xxx=510 to 545 in step of 5,
LFxxxM12-50H, xxx=470 to 505 in step of 5,
LFxxxM10-72H, xxx=520 to 555 in step of 5,
LFxxxM10-66H, xxx=480 to 505 in step of 5,
LFxxxM10-60H, xxx=435 to 460 in step of 5,
LFxxxM10-54H, xxx=390 to 415 in step of 5,
LFxxxM8-72H, xxx=420 to 465 in step of 5,
LFxxxM8-66H, xxx=390 to 425 in step of 5,
LFxxxM8-60H, xxx=355 to 385 in step of 5,
LFxxxM6-72H, xxx=380 to 415 in step of 5,
LFxxxM6-60H, xxx=320 to 345 in step of 5,
xxx is standing for rated output power at STC

Parameters:

Construction:	Framed, with Junction box, Cable and Connectors.
Safety Class:	Class II
Maximum System Voltage:	1500 V DC
Fire Safety Class:	Class C according to UL790
Test Laboratory:	Yangzhou Opto-Electrical Products Testing Institute; No. 10 West Kaifa Road, Yangzhou, 225009 Jiangsu, P. R. China

Tested according to:

IEC 61215-1:2016
IEC 61215-1-1:2016
IEC 61215-2:2016
IEC 61730-1:2016
IEC 61730-2:2016
EN 61215-1:2016
EN 61215-1-1:2016
EN 61215-2:2017
EN IEC 61730-1:2018
EN IEC 61730-1:2018/AC:2018-06
EN IEC 61730-2:2018
EN IEC 61730-2:2018/AC:2018-06